

IAPMO OCEANIA

7-11 Fullard Road, Narre Warren, Victoria 3805, Australia /info@iapmooceania.org



IAPMO oceania is a product certification body which inspects and arranges for the independent laboratory testing of samples taken from the manufacturer's stock or from the market or a combination of both, to verify compliance of the requirements of applicable Standards and Specifications. This activity is coupled with periodic surveillance of the certified product taken from the market place or the manufacturer's factory. This certification is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO oceania of the product acceptance by Authorities Having Jurisdiction.

GASMARK CERTIFICATE

IAPMO Oceania hereby grants to:

Uni-Geräte E. Mangelmann Elektrotechnische Fabrik GmbH

Holtumsweg 13, Weeze, Nordrhein-Westfalen 47652 Germany

Email: info@uni-geraete.com

the right to use the GasMark in accordance with IAPMO oceania Pty Ltd 'Mark Rules' on the product as described in the attached GasMark Schedule. The Certificate is granted subject to IAPMO oceania Pty Ltd 'Governance Rules'.

Evaluated to:

AS 4629.2:2022 Amdt 1

Automatically operated valves for use with gas Part 2: Vent valves

Manufacturer:

Refer to Certificate Holder

Certificate No.: GMK11022

First Certified: 08 Apr 2026

Certification Date: 08 Apr 2026

Expiry Date: 07 Apr 2031

A handwritten signature in black ink, reading "David Viola".

David Viola

Chief Executive Officer of the IAPMO Group

This GasMark certification is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of IAPMO R&T Oceania, or any evidence of non-compliance with applicable Standards, Specifications or of inferior workmanship, may be deemed sufficient cause for revocation of this certification. Reproduction of or reference to this certificate for advertising purposes may be made only by specific written permission of IAPMO oceania. Any alteration of this certificate could be grounds for revocation of this certification.



GASMARK SCHEDULE



Certificate Holder

Uni-Geräte E. Mangelmann Elektrotechnische Fabrik GmbH

A.B.N.:

Holtumsweg 13, Weeze, Nordrhein-Westfalen 47652 Germany

Manufacturer

Refer to Certificate Holder

Standards

AS 4629.2:2022 Amdt 1

Automatically operated valves for use with gas Part 2: Vent valves

Certificate No. GMK11022

Certification Date: 08 Apr 2026

Expiry Date: 07 Apr 2031

First Certified: 08 Apr 2026

Distributor	Brand Name	Model ID	Gas Type	Product Description	Pressure	Temperature	Variations
PACIFIC VALVE TECH & ENGINEERING PTY LTD	UNI-GERAETE	02- EVO *-4R	Component	Automatic vent valves	20 kPa	-20°C to 60°C	Threaded connection* = 3, 5, 7. Operating position - all valves vertical $\pm 5^\circ$, except 'W' suffix valves, suitable for vertical or horizontal. Optional position indicator. Supply voltage - 24 Vac to 230 Vac or 24 Vdc to 230 Vdc. Refer to Certificate Holder
PACIFIC VALVE TECH & ENGINEERING PTY LTD	UNI-GERAETE	1- EVO *-4R	Component	Automatic vent valves	100 kPa	-20°C to 60°C	Threaded connection* = 2, 3, 5, 7, 10. Operating position - all valves vertical $\pm 5^\circ$, except 'W' suffix valves, suitable for vertical or horizontal. Optional position indicator. Supply voltage - 24 Vac to 230 Vac or 24 Vdc to 230 Vdc. Refer to Certificate Holder
PACIFIC VALVE TECH & ENGINEERING PTY LTD	UNI-GERAETE	4- EVO *-4R	Component	Automatic vent valves	400 kPa	-20°C to 60°C	Threaded connection* = 2, 3, 5, 7. Operating position - all valves vertical $\pm 5^\circ$, except 'W' suffix valves, suitable for vertical or horizontal. Optional position indicator. Supply voltage - 24 Vac to 230 Vac or 24 Vdc to 230 Vdc. Refer to Certificate Holder
PACIFIC VALVE TECH & ENGINEERING PTY LTD	UNI-GERAETE	6- EVO *-4R	Component	Automatic vent valves	600 kPa	-20°C to 60°C	Threaded connection* = 3, 5. Operating position - all valves vertical $\pm 5^\circ$, except 'W' suffix valves, suitable for vertical or horizontal. Optional position indicator. Supply voltage - 24 Vac to 230 Vac or 24 Vdc to 230 Vdc. Refer to Certificate Holder
PACIFIC VALVE TECH & ENGINEERING PTY LTD	UNI-GERAETE	10- EVO 10-4R	Component	Automatic vent valves	1000 kPa	-20°C to 60°C	Threaded connection. Operating position - all valves vertical $\pm 5^\circ$, except 'W' suffix valves, suitable for vertical or horizontal. Optional position indicator. Supply voltage - 24 Vac to 230 Vac or 24 Vdc to 230 Vdc. Refer to Certificate Holder
PACIFIC VALVE TECH & ENGINEERING PTY LTD	UNI-GERAETE	25- EVSO 5-4R	Component	Automatic vent valves	2500 kPa	-20°C to 60°C	Threaded connection. Operating position - all valves vertical $\pm 5^\circ$, except 'W' suffix valves, suitable for vertical or horizontal. Optional position indicator. Supply voltage - 24 Vac to 230 Vac or 24 Vdc to 230 Vdc. Refer to Certificate Holder

Distributor	Brand Name	Model ID	Gas Type	Product Description	Pressure	Temperature	Variations
PACIFIC VALVE TECH & ENGINEERING PTY LTD	UNI-GERAETE	40- EVSO 5-4R	Component	Automatic vent valves	4000 kPa	-20°C to 60°C	Threaded connection. Operating position - all valves vertical $\pm 5^\circ$, except 'W' suffix valves, suitable for vertical or horizontal. Optional position indicator. Supply voltage - 24 Vac to 230 Vac or 24 Vdc to 230 Vdc. Refer to Certificate Holder
PACIFIC VALVE TECH & ENGINEERING PTY LTD	UNI-GERAETE	1- EVO *N-4R	Component	Automatic vent valves	100 kPa	-20°C to 60°C	Flanged connection* = 5, 7, 10, 12, 15, 20. Operating position - all valves vertical $\pm 5^\circ$, except 'W' suffix valves, suitable for vertical or horizontal. Optional position indicator. Supply voltage - 24 Vac to 230 Vac or 24 Vdc to 230 Vdc. Refer to Certificate Holder
PACIFIC VALVE TECH & ENGINEERING PTY LTD	UNI-GERAETE	1- EVO *N(H)-4R	Component	Automatic vent valves	100 kPa	-20°C to 60°C	Flanged connection* = 5, 7, 10, 12, 15, 20. Operating position - all valves vertical $\pm 5^\circ$, except 'W' suffix valves, suitable for vertical or horizontal. Optional position indicator. Supply voltage - 24 Vac to 230 Vac or 24 Vdc to 230 Vdc. Refer to Certificate Holder

END RECORD

END RECORD



David Viola
Chief Executive Officer of the IAPMO Group